D.T.P. (HQ) Member Secretary B.P.C.

S.T.P. (G) Member B.P.C.

C.T.P. (Hr.) Chairman B.P.C.

A.D | J.D KARISHAN KUMAR | S.D DEV KUMAR | P.A PREM KUMAR | A.T.P PRERNA SIHAG

7 / A108

LEGEND FOR VERTICAL PIPES

1. 110 OD uPVC SOIL & VENT PIPE
2. 110 OD uPVC WASTE & VENT PIPE
3. 75 OD uPVC ANTI SYPHONAGE PIPE
4. DOMESTIC WATER SUPPLY PIPE DN.TAKE PIPE
5. FLUSHING WATER SUPPLY PIPE DN.TAKE PIPE
6. DOMESTIC WATER SUPPLY FROM HYDROPNEUMATIC SYSTEM FOR UPPER THREE FLOORS.
7. HOT WATER PIPE FROM SOLAR TO M.BED ROOM
8. DOMESTIC RISER PIPE TO O.H.TANK
9. FLUSHING RISER PIPE TO O.H.TANK

(R) 110 OD uPVC RAIN WATER PIPE
(R1) 75 OD uPVC RAIN WATER PIPE

FT	FLOOR TRAP(110x110mm)
☒	CUTOUT(200x200mm)

Checked and found ok for Public Health (Internal) Services only subject to comments in forwarding letter No. SE(HQ)/ 35 Dt. 13.1.15

Superintending Engineer (HQ) HUDA, Panchkula

13/1/15

35530

1950 | 8930 | 6290 | 6180 | 5300 | 6880

OUTER WALL (200 MM) | BALCONY ABOVE | OUTER WALL (230 MM) | OUTER WALL (200 MM)

DRESS 1.55 X 2.10 | TOILET 1.55 X 2.55 | MASTER BEDROOM 3.50 X 4.20 | BEDROOM 3.10 X 4.20 | KITCHEN 2.00 X 4.20 | DRAWING 3.63 X 2.935 | UTILITY 1.42 X 1.90 | WC 1.20X1.80 | SERVANT ROOM 2.72 X 3.00 | DINING 4.10 X 3.665 | BEDROOM 3.40 X 3.665 | TOILET 1.55 X 2.465 | 1.10M WIDE UTILITY PASSAGE | 1.60M WIDE VESTIBULE | 0.75 LOBBY 7.670 X 2.60 | DN W:1250 MM T: 300 MM R: 150 MM | UP | GARBAGE PIT | LIFT SHAFT 1.910 X 1.910 (13 PAX) | LIFT SHAFT 1.910 X 3.00 (13 PAX) | KITCHEN 2.00 X 4.40 | DRAWING/ DINING 3.360 X 6.10 | 1.05M WIDE PASSAGE | BEDROOM 3.05 X 3.90 | MASTER BEDROOM 3.30 X 5.05 | TOILET 1.525 X 2.45 | W:1520 MM T: 300 MM R: 150 MM | ENTRANCE LOBBY 5.720 X 6.90 | HANDICAP RAMP SLOPE - 1:12

PROJECTION 600MM

17630

1950 | 8930 | 6320 | 6120 | 5330 | 6880

12 / A-A108

8 / A108

For Universe Heights (India) Pvt. Ltd.

Authorised Signatory

UNIVERSE HEIGHTS (INDIA) PVT. LTD.

SUBMISSION DRAWING

DRW No- SER 01

TOWER A-C GROUND FLOOR